



171412340674

江西省贝源检测技术有限公司



报 告 声 明

1、本公司保证检测的科学性、公正性和准确性，对检测数据负检测技术责任，并对委托单位提供的样品和技术资料保密。

2、对本报告如有疑问，请同报告至宣调，来函来电请注明报告编号。对检测结果若有异议，请于收到本报告之日起十个工作日内向报告室提出复检申请。对于性能不稳定的样品，恕不受理复检。

3、本报告由本公司书面批准，不得部分复制、修改、删减、或用于其他目的。

一、检测说明

受鄱阳县绿色东方再生能源有限公司委托，对该单位的废气进行检测。

单位名称：鄱阳县绿色东方再生能源有限公司

地址：江西省上饶市鄱阳县绿色东方再生能源有限公司

联系电话：15507369259

三、检测内容

废气	砷	空气和废气 颗粒物中铅等金属元素的测定 电感耦合等离子体质谱法（HJ 657-2013）	自动烟尘（气）测试仪 ZR3266 JX-BY(c)-51(01) 电感耦合等离子体质谱仪 Nexlon1000/JX-BY(a)-23	0.2μg/m ³	
	铅			0.2μg/m ³	
	总铬			0.3μg/m ³	
	锰			0.05μg/m ³	
	镍			0.1μg/m ³	
	钴			0.02μg/m ³	
	铜			0.2μg/m ³	
	铝			0.008μg/m ³	

表3 检测人员和时间



表 4 检测项目参考标准一览表

[illegible]

This is a detailed architectural floor plan of a large, multi-story building. The plan shows a complex arrangement of rooms, corridors, and service areas. Key features include a large central hall, numerous smaller offices or meeting rooms, and a series of rooms along the perimeter. The drawing is in black ink on a white background, with various lines indicating walls, doors, and furniture. There are also some handwritten notes and annotations throughout the plan.

续表 5 废气检测结果

项目类别	有组织废气	检测类别	☐ 送检 ☒ 委托抽/采样				
采样时间	2025.02.06						
治理设施	废气经布袋除尘+干法脱硝(半干法脱硝)+活性炭吸附处理后由 80m 高排气筒排放						
烟气参数	排放口名称	检测项目	检测频次	烟温 (℃)	含氧量 (%)	流速 (m/s)	含氧量 (%)
	焚烧炉废气处理 后排放口	砷、镉、铜、锰、铈、镍	小时 均值	140.8	12.24	17.6	8.8
		检 测 结 果					
采样点位	检测项目	检测频次	废气量 m ³ /h	实测浓度 mg/m ³	折算浓度 mg/m ³	排放速率 t/a/h	标准限值 mg/m ³
焚烧炉 废气处 理后 排放口	铬	小时	116507	3.53×10 ⁻³	2.89×10 ⁻³	4.1×10 ⁻⁴	/
	砷		116507	0.0196	0.0161	2.3×10 ⁻³	/
	铜		116507	6.54×10 ⁻³	5.69×10 ⁻³	8.1×10 ⁻⁴	/
	铈	均值	116507	1.35×10 ⁻³	1.11×10 ⁻³	1.6×10 ⁻⁴	/
	铅		116507	0.0332	0.0272	3.9×10 ⁻³	/
	镉						



附图:

